

CASWELL COUNTY ENVIRONMENTAL HEALTH

144 MAIN STREET, P.O. BOX 1406, YANCEYVILLE, NC 27379/ (336) 694-9731, FAX (336) 694-5547

CONSTRUCTION AUTHORIZATION

Section II: Construction Authorization (Required for Building Permit)

<input checked="" type="checkbox"/> New <input type="checkbox"/> Repair <input type="checkbox"/> Expansion		Property Location: 134 ROCK QUARRY RD	
Facility Type: SFD			
Type of Wastewater System: <i>Initial</i> IIIIG	<i>Repair</i> IIIIG	Basement Present: NO Basement Fixtures: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Wastewater Flow (GPD): 360gpd	Number of Occupants: 6	<i>See "Authorization Conditions" below</i>	
Installation Requirements/Conditions:			
Septic Tank Size (Gallons): 1000	Total Trench Length (Feet): 300' 25% reduction	Trench Spacing(Feet on Center): 9	
Pump Tank Size (Gallons):	Trenches shall be installed on contour at a maximum trench depth of (Inches):		24
Pump Requirements (Feet):		Aggregate Depth (Inches):	Below Pipe: NA Above Pipe: NA Total (Inches): NA Soil Cover (Inches): 12
TDH vs. _____	GPM _____		
Authorization Conditions:			

CASWELL COUNTY ENVIRONMENTAL HEALTH

144 MAIN STREET, P.O. BOX 1406, YANCEYVILLE, NC 27379/ (336) 694-9731, FAX (336) 694-5547

IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION

ISSUED TO: DAVID AND HALEY GEIGER	PIN: 0017 005	PERMIT NUMBER: 2764
--	----------------------	----------------------------

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958 and .1959 are incorporated by reference into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. **This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.**

Authorized State Agent:



Date of Issuance:

04/19/2023

SEE ATTACHED SITE SKETCH


ISSUED TO:

DAVID AND HALEY GEIGER

PIN 0017 005

PERMIT NUMBER:

2764



PERMIT TO CONSTRUCT PRIVATE DRINKING WATER WELL

(Permit Expires 5 Years from Date Issued)

Applicant Information

DAVID AND HALEY GEIGER

336-517-9838

Name Telephone Number

6011 APPLE WYRICK RD, GIBSONVILLE, NC

Address

Well Identification

Physical Location ROCK QUARRY RD

Contractor Cert #: _____

GPS Location Lat: _____

Long: _____

Well Contractor: _____

Well Head Inspection

Well Contractor Identification Plate

Pump Installer Identification Plate

Sample Tap

Access Port / Vent

Well Seal

Well Head 12 inches/Pitless Adaptor 8 inches above Grade

Grout to Ground Surface

CONDITIONS

See Site Plan

Maintain 25' from well to foundation

50' from well to Septic System

Attachments

- Form GW-1a Form GW-30 Water Plat/Site Plan

Well Inspection Record

Permit Issued By: *Dennis Powell* Date: 04/19/2023

Grout Inspection: _____ Date: _____ or _____

Contractor Certification for Grouting Not Witnessed by Department Date: _____

Well Head Inspection: _____ Date: _____

Certificate of Completion

Construction has been completed, a Residential Well Construction Record Form GW-1a has been submitted, and inspections have been completed in accordance with 15A NCAC 02C.

Certification by: _____ Date: _____

Water Samples Collected By: _____ Date: _____